S choo l N a m e Locatio n Typ e Location Description Sampled Date Method Parameter Result (ug/L) Qualifier MDL PQL

Joh n F Kenne dy Hig h WCCUSD

Fou ntai n Ri ght dri nk ing f ountai n cl osest to 13 1, in ha ll w ay 11 /1 3/2 01 9

EPA-2 00 .8 Lead

0. 21 J

0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap 3 basin wash sink, right tap in cafeteria kitchen 11/13/2019 EPA-200.8 Lead 0.21 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain Water fountain between rooms 804 and 803, in the hallway 11/13/2019 EPA-200.8 Lead 9.6 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain Fountain attached to sink in back room of 206 11/13/2019 EPA-200.8 Lead 4.6 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain Lower fountain in between rooms 408 and 406, in hallway 11/13/2019 EPA-200.8 Lead 0.73 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD

Fou ntai n Left side of d ouble fou ntai n outsid e room 30 3, i n hal lw ay 11 /1 3/2 01 9

EPA-2 00 .8 Lead

0. 42 J

0.1 1

Joh n F Kenne dy Hig h WCCUSD Water DispenserWater bottle dispenser on left side of the library entrance. 11/13/2019 EPA-200.8 Lead 1.8 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap on the right side of sink between rooms 404 and 40211/13/2019 EPA-200.8 Lead 5.9 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Station 8 sink near lab preparation 405 11/13/2019 EPA-200.8 Lead 1.7 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Sink in staff kitchen inside room 503 11/13/2019 EPA-200.8 Lead 0.36 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Water DispenserWater bottle fountain to the right of employee bathroom in room 500, right side of fountain 11/13/2019 EPA-200.8 Lead 0.24 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain Water fountain around the corner from staff men bathroom 11/13/2019 EPA-200.8 Lead 0.14 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap on left side of sink in gym snack shack 11/13/2019 EPA-200.8 Lead 59 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain Fountain on right side of sink to the left when you walk into room 605 11/13/2019 EPA-200.8 Lead 29 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Left sink in back counter of concession stand on football field 11/13/2019 EPA-200.8 Lead 2.2 0.1 1

Joh n F Kenne dy Hig h WCCUSD Water DispenserBottle filler in cafeteria 11/13/2019 EPA-200.8 Lead 0.87 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Lone Tap in kitchen near office 11/13/2019 EPA-200.8 Lead 0.44 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain DF in side room of room 803 11/13/2019 EPA-200.8 Lead 5.1 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain DF in classroom 204 11/13/2019 EPA-200.8 Lead 3.8 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in classroom 406 11/13/2019 EPA-200.8 Lead 1.2 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in classroom 408 11/13/2019 EPA-200.8 Lead 0.72 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in file room through dean's office 11/13/2019 EPA-200.8 Lead 0.82 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in classroom 410 11/13/2019 EPA-200.8 Lead 0.64 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in classroom 401 11/13/2019 EPA-200.8 Lead 1.2 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in room 501 11/13/2019 EPA-200.8 Lead 1.5 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in health educator room in room 505 11/13/2019

EPA-2 00 .8 Lead

1.7

0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in exam room 2, in room 505 11/13/2019 EPA-200.8 Lead 1.1 0.1 1

John F Ke nnedy High S a m ple Resu lts

Joh n F Kenne dy Hig h WCCUSD

Tap Ta p in l ab i n room 50 5 11 /1 3/2 01 9

EPA-2 00 .8 Lead

1.6

0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in classroom 506 11/13/2019 EPA-200.8 Lead 0.96 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain Left side of pink DF in girls locker room. 11/13/2019 EPA-200.8 Lead 2.6 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain DF in girls locker room 11/13/2019 EPA-200.8 Lead 10 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain DF next to sink in classroom 604 11/13/2019 EPA-200.8 Lead 1.4 0.1 1

Joh n F Kenne dy Hig h WCCUSD Fountain DF in room 600 (wood shop) 11/13/2019 EPA-200.8 Lead 1.1 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in printing room of fab lab (room 60 1) 11 /13/2019 EPA-200.8 Lead 0.22 J 0.1 1

Joh n F Kenne dy Hig h WCCUSD Tap Tap in r r r r r r r r r r r r r Ƈ谀 S r rr Ƈ谀 S r rr Ƈ谀 S r rr Ƈ谀 S��0P ؀8㖓耶쀀2r 9