

School Name	Location Type	Location Description	Sampled Date	Method	Parameter	Result (ug/l)	Qualifier	MDI	PQ
Ioway Dale Middle School	Fountain	Upper DF in main admin hallway	11/19/2019	HPA-2008	Lead	011	J	01	1
Ioway Dale Middle School	Tap	Tap in room A104 (workroom)	11/19/2019	HPA-2008	Lead	032	J	01	1
Ioway Dale Middle School	Tap	Tap in classroom B104	11/19/2019	HPA-2008	Lead	078	J	01	1
Ioway Dale Middle School	Tap	Tap in classroom B102	11/19/2019	HPA-2008	Lead	015	J	01	1
Ioway Dale Middle School	Fountain	Lower DF upstairs in building Bin between classrooms B301 and B303	11/19/2019	HPA-2008	Lead	ND		01	1
Ioway Dale Middle School	Tap	Tap in room C104	11/19/2019	HPA-2008	Lead	050	J	01	1
Ioway Dale Middle School	Tap	Tap in room C204	11/19/2019	HPA-2008	Lead	053	J	01	1
Ioway Dale Middle School	Tap	Tap in workroom C207	11/19/2019	HPA-2008	Lead	066	J	01	1
Ioway Dale Middle School	Tap	Tap in workroom D107	11/19/2019	HPA-2008	Lead	18		01	1
Ioway Dale Middle School	Fountain	Lower DF in building Don 2nd floor in between classrooms D301 and D303	11/19/2019	HPA-2008	Lead	011	J	01	1
Ioway Dale Middle School	Fountain	Upper DF on gasside of main admin building outside	11/19/2019	HPA-2008	Lead	060	J	01	1
Ioway Dale Middle School	Fountain	Gym building lower DF across from classroom F101	11/19/2019	HPA-2008	Lead	ND		01	1
Ioway Dale Middle School	Fountain	Upper DF in girls locker room	11/19/2019	HPA-2008	Lead	032	J	01	1
Ioway Dale Middle School	Fountain	DF in classroom F104	11/19/2019	HPA-2008	Lead	17		01	1
Ioway Dale Middle School	Tap	Tap in snack bar room G132	11/19/2019	HPA-2008	Lead	85		01	1
Ioway Dale Middle School	Tap	Tap in NE corner on main kitchen area	11/19/2019	HPA-2008	Lead	15		01	1
Ioway Dale Middle School	Fountain	DF in main Cafeteria area (not entry way)	11/19/2019	HPA-2008	Lead	038	J	01	1
Ioway Dale Middle School	Fountain	DF in classroom G112	11/19/2019	HPA-2008	Lead	027	J	01	1
Ioway Dale Middle School	Tap	Tap in room A207 workroom	11/19/2019	HPA-2008	Lead	061	J	01	1

**Lowry Dale Middle School**

**Fountain**

**Upper adjacent to stairs rear mE105 electric**

**11/19/2019**